

CERTIFICATE

of constancy of performance

1922 - CPR - 1185

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fire detection and fire alarm systems. Smoke detectors. Point detectors using scattered light, transmitted light or ionization - optical infra-red smoke detector FS C30, with mounting base FS C01

(with the performance listed, see Annex I to 1922-CPR-1185 that is an inseparable part of this certificate)

placed on the market under the name or trade mark of
FS Yangin ve Güvenlik Sistemleri San. Tic. A.Ş.

Hocaalizade Mahallesi 6 Kültür Sokak, Adalaet İşhane No:12/401, 16010 Bursa, Osmangazi, Turkey

and produced in the manufacturing plant of
Identification code 001

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard


EN 54-7:2000, EN 54-7:2000/A1:2002, EN 54-7:2000/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 08.07.2019 and will remain valid until 08.07.2020 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Issued:
Burgas, 08 July 2019



Manager:


Dedal
Attestation &
Certification

arch. Galina Vasileva