

CERTIFICATE

of constancy of performance

1922 - CPR - 1183

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fire detection and fire alarm systems. Heat detectors. Conventional heat detector FS C10 and FS C20, with mounting base FS C01

(with the performance listed, see Annexes I and II to 1922-CPR-1183 that are an inseparable part of this certificate)

placed on the market under the name or trade mark of
FS Yangin ve Güvenlik Sistemleri San. Tic. A.Ş.

Hocaalizade Mahallesi 6 Kültür Sokak, Adalaet İşhane №12/401, 16010 Bursa, Osmangazi, Turkey

and produced in the manufacturing plant of
Identification code 001

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 54-5:2000, EN 54-5:2000/A1:2002

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 08.07.2019 and will remain valid until 08.07.2020 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Manager:

arch. Galina Vasileva